

Details on Fire Penetrations and Soudal Products

Fire related products and where they can be used:

Due to an updated interpretation of the NZBC regarding the specification and certification of fire Rated jointing and Penetrations you need to pass on the following:

- All Fire Rated Linier Joint design is covered by the requirements of AS1530.4
- All Fire Rated Penetration design is covered by the requirements of AS4072.1
- Soudal Fire Rated Product family includes the following items:

Product Code	Product Description
20160	Gorilla FR Expanding Foam Click&Fix 750ml
20169	Gorilla FR Expanding Foam Click&Fix 750ml
20060	Gorilla Firecryl FR Firerated Sealant 310ml White
21427	Gorilla Firecryl FR Firerated Sealant 600ml Grey
20165	Gorilla Firesil FR Firerated Silicone
56219	Gorilla MS Firestop FR Firerated Sealant 600ml Grey

The following **Linier Joint design** (horizontal & vertical) are covered by the Soudal Fire Rated Product Certificates:

- Linier Joints are covered of between 10mm -40mm. This covers both Internal and externally located joints in walls and between walls and ceilings.
- Please check the Appropriate Fire Report for specific details
- Depending on report the Holdfast Products have been tested on Concrete and Aerated Concrete.

- Soudal products tested are;

Gorilla Expanding Foam FR

Gorilla Firecryl

Gorilla Firestop MS

Gorilla Firesil



MIN
229 minutes
Integrity

** Refer to appropriate Fire Test Report and Fire Guide